

Swimming Pool Bonding Integrity Test

Name: _____

Date : _____

Address: _____

Inspection of swimming pools – No certificate of compliance will be issued without a valid bonding integrity test performed by a licensed electrician and/or qualified testing agency.

A low impedance instrument capable of measuring .01 ohm shall be used.
 The lead conductor used in the measurement shall be calculated and deducted from readings.

A test of applicable test points such as filter motors housing, ladders, diving board, safety line eyelet, water heaters or any other associated metal components shall be performed at least twice and tabulated.

Point of Test	Readings in Ohms		Point of Test	Readings in Ohms	
	TEST 1	TEST 2		TEST 1	TEST 2

The resistance between any one points shall be low enough to eliminate any voltage gradients in the pool area as prescribed in Article 680.26 Equipotential Bonding.
 Spas and Hot Tubs shall comply with the provisions of Parts I and II of Article 680 except as modified by 680.42(A) and (B), 680.43. Fountains, Signs Part V, Therapeutic Use Tubs and Pools Part VI.

Test Data must be verified by electricians signature, license number and date.

 Electrician Print Name

 License Number

 Date

 Electrician Signature

 Address

Mail results to: **Electrical Inspectors, Inc.**, 300 East Meadow Avenue, East Meadow, NY 11554 or Fax (516) 794-5854